

V150-4.2 MW 50 Hz, PO1, 228051

Results of acoustic noise measurements according to IEC 61400-11 Edition 3.0

Vestas Wind Systems A/S

Report No.: 10163788-A-1-A

Date: 2019-08-26



IMPORTANT NOTICE AND DISCLAIMER

1. This document is intended for the sole use of the Client as detailed on the front page of this document to whom the document is addressed and who has entered into a written agreement with the DNV GL entity issuing this document ("DNV GL"). To the extent permitted by law, neither DNV GL nor any group company (the "Group") assumes any responsibility whether in contract, tort including without limitation negligence, or otherwise howsoever, to third parties (being persons other than the Client), and no company in the Group other than DNV GL shall be liable for any loss or damage whatsoever suffered by virtue of any act, omission or default (whether arising by negligence or otherwise) by DNV GL, the Group or any of its or their servants, subcontractors or agents. This document must be read in its entirety and is subject to any assumptions and qualifications expressed therein as well as in any other relevant communications in connection with it. This document may contain detailed technical data which is intended for use only by persons possessing requisite expertise in its subject matter.
2. This document is protected by copyright and may only be reproduced and circulated in accordance with the Document Classification and associated conditions stipulated or referred to in this document and/or in DNV GL's written agreement with the Client. No part of this document may be disclosed in any public offering memorandum, prospectus or stock exchange listing, circular or announcement without the express and prior written consent of DNV GL. A Document Classification permitting the Client to redistribute this document shall not thereby imply that DNV GL has any liability to any recipient other than the Client.
3. This document has been produced from information relating to dates and periods referred to in this document. This document does not imply that any information is not subject to change. Except and to the extent that checking or verification of information or data is expressly agreed within the written scope of its services, DNV GL shall not be responsible in any way in connection with erroneous information or data provided to it by the Client or any third party, or for the effects of any such erroneous information or data whether or not contained or referred to in this document.
4. Any wind or energy forecasts estimates or predictions are subject to factors not all of which are within the scope of the probability and uncertainties contained or referred to in this document and nothing in this document guarantees any particular wind speed or energy output.

KEY TO DOCUMENT CLASSIFICATION

| | | |
|--------------------------|---|---|
| Strictly Confidential | : | For disclosure only to named individuals within the Client's organisation. |
| Private and Confidential | : | For disclosure only to individuals directly concerned with the subject matter of the document within the Client's organisation. |
| Commercial in Confidence | : | Not to be disclosed outside the Client's organisation. |
| DNV GL only | : | Not to be disclosed to non-DNV GL staff |
| Client's Discretion | : | Distribution for information only at the discretion of the Client (subject to the above Important Notice and Disclaimer and the terms of DNV GL's written agreement with the Client). |
| Published | : | Available for information only to the general public (subject to the above Important Notice and Disclaimer). |

© 2019 DNV GL, All rights reserved

| | | |
|-----------------|--|---|
| Project name: | V150-4.2 MW 50 Hz, PO1, 228051 | DNV GL - Energy |
| Report title: | Results of acoustic noise measurements according to IEC 61400-11 Edition 3.0 | Renewables Measurements GL Garrad Hassan Deutschland GmbH |
| Customer: | Vestas Wind Systems A/S, Hedeager 42, 8200 Aarhus N, Denmark | Sommerdeich 14b 25709 Kaiser-Wilhelm-Koog Germany |
| Contact person: | Niels Christian M. Nielsen | Tel: +49 4856 901 0 |
| Date of order: | 2019-06-10 | HR B 636 ME |
| Project No.: | 10163788 | |
| Report No.: | 10163788-A-1-A | |

Task and objective:

Noise emission measurement according to IEC 61400-11 Edition 3.0 on a wind turbine of type Vestas V150-4.2 MW 50 Hz near Østerild in Denmark.

Prepared by:

Verified by:

Approved by:



Dr. rer. Nat. Ivan Asin Cruz
(Project engineer)



Dipl.-Ing. (FH) Ulf Kock
(Senior Project engineer)



Dipl.-Ing. Klaus Buchmann
(Head of Section Acoustics)

- Strictly Confidential
- Private and Confidential
- Commercial in Confidence
- DNV GL only
- Client's Discretion
- Published

Reference to part of this report which may lead to misinterpretation is not permissible.

| Rev. No. | Date | Reason for Issue | Prepared by | Verified by | Approved by |
|----------|------------|------------------|----------------|-------------|----------------|
| A | 2019-08-26 | First issue | Ivan Asin Cruz | Ulf Kock | Klaus Buchmann |



Deutsche
Akkreditierungsstelle
D-PL-11134-01-00

This report in excerpts may only be copied with written consent of GL Garrad Hassan Deutschland GmbH. It totally consists 87 pages incl. all annexes.

GL Garrad Hassan Deutschland GmbH
Registered in Germany, Amtsgericht Pinneberg, No. HR B 636 ME.
Registered Office: Sommerdeich 14 b, 25709 Kaiser-Wilhelm-Koog, Germany.
Place of performance and jurisdiction is Hamburg. Managing Directors: Dr. Andreas Schröter, Marko Ibsch.
The latest edition of the General Terms and Conditions of GL Garrad Hassan Deutschland GmbH is applicable. German law applies

Table of contents

| | | |
|-------|--|----|
| 1 | EXECUTIVE SUMMARY | 1 |
| 2 | INTRODUCTION | 1 |
| 3 | METHODS | 1 |
| 3.1 | Measurement procedure | 1 |
| 3.2 | Measurement object | 2 |
| 3.3 | Course of measurements | 2 |
| 3.4 | Measuring equipment | 3 |
| 3.5 | Position of microphone | 3 |
| 3.6 | Position of met mast | 3 |
| 4 | MEASUREMENT RESULTS | 3 |
| 4.1 | Determination of noise directivity | 3 |
| 4.2 | Sound pressure level | 4 |
| 4.3 | Sound power level | 5 |
| 4.4 | Tonal and frequency analysis | 6 |
| 4.5 | One-third octave analysis | 6 |
| 4.6 | Uncertainties | 6 |
| 4.6.1 | Type B uncertainties | 6 |
| 4.6.2 | Uncertainty on the wind speed | 7 |
| 4.6.3 | Uncertainty on the average sound spectra | 8 |
| 4.6.4 | Uncertainty on the noise levels at bin centres | 9 |
| 4.6.5 | Uncertainty on the total noise level | 9 |
| 4.6.6 | Sound power level | 10 |
| 4.6.7 | Uncertainty on the tonality analysis | 10 |
| 5 | DEVIATIONS | 10 |
| 6 | CONCLUSIONS | 11 |
| 7 | REFERENCES | 12 |
| 8 | LIST OF ABBREVIATIONS | 13 |
| 9 | APPENDIX | 13 |
| 9.1 | L_{Aeq} vs. wind speed at hub height | 14 |
| 9.2 | Summary of the results according to hub height | 15 |
| 9.3 | L_{Aeq} vs. wind speed at 10 m height | 16 |
| 9.4 | Summary of the results according to 10 m height | 17 |
| 9.5 | Measured wind speed at 10 m height vs. wind speed from power curve | 18 |
| 9.6 | Measured wind speed at hub height vs. wind speed from power curve | 19 |
| 9.7 | L_{Aeq} vs. active power | 20 |
| 9.8 | Rotor speed vs. active power | 21 |
| 9.9 | Rotor speed vs. wind speed at hub height | 22 |
| 9.10 | Time plot of measurement (page 1) | 23 |
| 9.11 | Time plot of measurement (page 2) | 24 |
| 9.12 | Time plot of measurement (page 3) | 25 |
| 9.13 | Third-octave sound power spectra at a WS of 7.5 m/s at hub height | 26 |

| | | |
|------|---|----|
| 9.14 | Third-octave sound power spectra at a WS of 8.0 m/s at hub height | 27 |
| 9.15 | Third-octave sound power spectra at a WS of 8.5 m/s at hub height | 28 |
| 9.16 | Third-octave sound power spectra at a WS of 9.0 m/s at hub height | 29 |
| 9.17 | Third-octave sound power spectra at a WS of 9.5 m/s at hub height | 30 |
| 9.18 | Third-octave sound power spectra at a WS of 10.0 m/s at hub height | 31 |
| 9.19 | Third-octave sound power spectra at a WS of 10.5 m/s at hub height | 32 |
| 9.20 | Third-octave sound power spectra at a WS of 11.0 m/s at hub height | 33 |
| 9.21 | Third-octave sound power spectra at a WS of 11.5 m/s at hub height | 34 |
| 9.22 | Third-octave sound power spectra at a WS of 12.0 m/s at hub height | 35 |
| 9.23 | Third-octave sound power spectra at a WS of 12.5 m/s at hub height | 36 |
| 9.24 | Third-octave sound power spectra at a WS of 13.0 m/s at hub height | 37 |
| 9.25 | Third-octave sound power spectra at a WS of 13.5 m/s at hub height | 38 |
| 9.26 | Third-octave sound power spectra at a WS of 14.0 m/s at hub height | 39 |
| 9.27 | Third-octave sound power spectra at a WS of 5 m/s at 10 m height | 40 |
| 9.28 | Third-octave sound power spectra at a WS of 6 m/s at 10 m height | 41 |
| 9.29 | Third-octave sound power spectra at a WS of 7 m/s at 10 m height | 42 |
| 9.30 | Third-octave sound power spectra at a WS of 8 m/s at 10 m height | 43 |
| 9.31 | Third-octave sound power spectra at a WS of 9 m/s at 10 m height | 44 |
| 9.32 | Tonality analysis - $\Delta L_{pn,j}$ and $\Delta L_{a,k}$ vs. frequency | 45 |
| 9.33 | Tonality analysis - rpm vs. frequency for the identified tones in the total noise (0-5000 Hz) | 46 |
| 9.34 | Tonality analysis - rpm vs. frequency for the identified tones in the total noise (40-600 Hz) | 47 |
| 9.35 | Tonality analysis - wind bin overview (page 1) | 48 |
| 9.36 | Tonality analysis - wind bin overview (page 2) | 49 |
| 9.37 | Tonality analysis - wind bin overview (page 3) | 50 |
| 9.38 | Tonality analysis - wind bin overview (page 4) | 51 |
| 9.39 | Frequency spectra of total and background noise at a WS of 7.5 m/s at hub height | 52 |
| 9.40 | Frequency spectra of total and background noise at a WS of 8.0 m/s at hub height | 53 |
| 9.41 | Frequency spectra of total and background noise at a WS of 8.5 m/s at hub height | 54 |
| 9.42 | Frequency spectra of total and background noise at a WS of 9.0 m/s at hub height | 55 |
| 9.43 | Frequency spectra of total and background noise at a WS of 9.5 m/s at hub height | 56 |
| 9.44 | Frequency spectra of total and background noise at a WS of 10.0 m/s at hub height | 57 |
| 9.45 | Frequency spectra of total and background noise at a WS of 10.5 m/s at hub height | 58 |
| 9.46 | Frequency spectra of total and background noise at a WS of 11.0 m/s at hub height | 59 |
| 9.47 | Frequency spectra of total and background noise at a WS of 11.5 m/s at hub height | 60 |
| 9.48 | Frequency spectra of total and background noise at a WS of 12.0 m/s at hub height | 61 |
| 9.49 | Frequency spectra of total and background noise at a WS of 12.5 m/s at hub height | 62 |
| 9.50 | Frequency spectra of total and background noise at a WS of 13.0 m/s at hub height | 63 |
| 9.51 | Frequency spectra of total and background noise at a WS of 13.5 m/s at hub height | 64 |
| 9.52 | Frequency spectra of total and background noise at a WS of 14.0 m/s at hub height | 65 |
| 9.53 | Power curve used for the analysis | 66 |
| 9.54 | Manufacturer's certificate (page 1) | 67 |
| 9.55 | Manufacturer's certificate (page 2) | 68 |
| 9.56 | Manufacturer's certificate (page 3) | 69 |
| 9.57 | Measuring equipment | 70 |
| 9.58 | Calibration certificate of noise level meter (page 1) | 71 |
| 9.59 | Calibration certificate of noise level meter (page 2) | 72 |
| 9.60 | Calibration certificate of noise level meter (page 3) | 73 |

| | | |
|------|---|----|
| 9.61 | Calibration certificate of noise level meter (page 4) | 74 |
| 9.62 | Calibration certificate of noise level meter (page 5) | 75 |
| 9.63 | Calibration certificate of noise level meter (page 6) | 76 |
| 9.64 | Calibration certificate of noise level meter (page 7) | 77 |
| 9.65 | Calibration certificate of anemometer (page 1) | 78 |
| 9.66 | Calibration certificate of anemometer (page 2) | 79 |
| 9.67 | Calibration certificate of anemometer (page 3) | 80 |
| 9.68 | Calibration certificate of anemometer (page 4) | 81 |
| 9.69 | Calibration certificate of anemometer (page 5) | 82 |
| 9.70 | Extract of the calibration certificate of secondary wind screen | 83 |
| 9.71 | Position of the test site | 84 |
| 9.72 | Photos | 85 |

1 EXECUTIVE SUMMARY

This report describes methods and results of a noise emission measurement according to IEC 61400-11 Edition 3.0 on a wind turbine generator system Vestas V150-4.2 MW 50 Hz near Østerild in Denmark.

2 INTRODUCTION

The order from Vestas Wind Systems A/S dated 2019-06-10 required GL Garrad Hassan Deutschland GmbH (GH-D) to carry out acoustic noise measurements on the wind turbine generator system (WTGS or 'turbine') Vestas V150-4.2 MW 50 Hz of hub height 137 m near Østerild in Denmark. From this turbine the sound power level and frequency spectra, emitted at different wind speeds, have been determined.

The results given in this report relate only to the specific turbine, weather conditions and site. The mentioned results in this report cannot be transferred to other turbines.

3 METHODS

3.1 Measurement procedure

The measurements of the acoustical emissions are performed in accordance with the legacy GH-D management system procedure /2/. This test procedure is an integral part of the management system of DNV GL.

All measurements and analysis described in this report were done in accordance with /2/ in combination with IEC 61400-11 Ed. 3.0 Wind Turbines, Part 11: Acoustic Noise Measurement Techniques, 2012-11-07 /1/.

According to /1/ the sound power level has to be analysed for wind speeds from 0.8 to 1.3 times the wind speed at 85 % of maximum power rounded to the bin centres.

Note: A measured power curve for the turbine was provided by the customer for purposes of converting the measured turbine power output into the standardised wind speed. This power curve is given in the annex.

3.2 Measurement object

Table 3-1 shows the characteristics of the measured WTGS. The remaining characteristics can be found in the manufacturer's certificate in the annex.

Table 3-1 Characteristics of the measured WTGS

| Parameter | Value |
|--|--|
| Manufacturer | Vestas |
| Type | Vestas V150-4.2 MW 50 Hz |
| Mode | PO1 |
| Rated Power | 4200 kW |
| Site | Østerild |
| Turbine serial no. | 228051 |
| Hub-height above ground | 137 m |
| Rotor diameter | 150 m |
| Distance middle of tower to middle of blade flange | 4.5 m |
| Gearbox type | ZF, EH1052A |
| Generator type | Vestas, 3 Phase IG, VND DASG 560/6M |
| Rotor blades | Vestas Wind Systems A/S, Vestas 73.65m |
| Blade additional components | Serrated trailing edges |
| Power control (pitch/stall) | Pitch |

3.3 Course of measurements

The total measurement period lasted from 2019-06-26 08:30 h until 2019-06-26 22:00 h. During turbine operation the measured wind speed at hub height ranged from 5.8 to 17.7 m/s. The real electrical power output of the turbine ranged between 959 and 4213 kW.

The turbine was running continuously during the operating noise measurements. The sound pressure level was measured with a microphone on an acoustically hard board and fed into a sound level meter. The calculated A-weighted equivalent 1-second average data and the non-acoustic data were acquired by the measurement system with a sampling rate of 1 Hz. Time periods with intermittent background noise of a significant nature, e.g. passing cars, planes flying over, rain etc., were marked accordingly during the measurements and are omitted in the later evaluation. If there were random and reoccurring disturbances which could not be marked during the measurement, a later state correction by means of a comparison with the audio-recording is done.

The wind turbine generator system is sited in farmland. The surface is covered by grass/plants, therefore a typical length of 0.05 m is assumed in the following. The microphone position was chosen to minimise the effect of buildings, trees or bushes in the surrounding area of the wind turbine generator system, which might have had an influence on the measurement results. The conditions comply with free field behaviour over a reflecting plane.

During the noise measurements the meteorological conditions given in Table 3-2 were prevailing.

Table 3-2 Prevailing meteorological conditions during the measurements

| Parameter | Value |
|--|----------------|
| Barometric pressure at 2 m height above ground [hPa] | 1016 - 1018 |
| Air temperature at 2 m height above ground [°C] | 14.2 - 18.8 |
| Prevailing wind direction | NW |
| Range of wind direction [°] | 252 - 354 |
| Weather conditions | Dry and bright |

3.4 Measuring equipment


The used measuring equipment is listed in the annex. The equipment is tested regularly according to the management system support function /3/ which includes the requirements of the /1/ to ensure a high degree of measurement accuracy as well as data security. The complete acoustic measurement system was checked before and after the measurements using an acoustic calibrator.

3.5 Position of microphone

The microphone was placed according to /1/. The distance from the turbine to the reference measuring point, $R_0 = 212.0$ m, was chosen taking local circumstances into account. The height of the microphone with respect to the bottom of the turbine foundation was $h_A = 0.0$ m.

3.6 Position of met mast

To gain results of free wind at the turbine position the met mast was located at the marked area in Figure 1. The aim is to measure the wind speed and wind direction in free-wind conditions by means of an anemometer and wind vane mounted on a 10 m met mast. The wind speed measured at the met mast is used for background noise measurements.

**Figure 1: Position of the met mast**

4 MEASUREMENT RESULTS

4.1 Determination of noise directivity

As no significant noise directivity was ascertained the reference noise measurement position was chosen to be directly downwind of the turbine. This position ensured that the worst-case sound propagation conditions were taken into account.

4.2 Sound pressure level

The microphone converts the sound pressure into a continuous analogue signal which is then fed to a sound level meter. The resulting dB value (L_{Aeq}) together with the status, the wind speed (WS) at a height of 10 m ($V_{z,m}$) and the measured power output (P_m) of the turbine, all recorded by the measurement system, is plotted against time in a graph given in the annex 9.10.

Here it can be seen at which points in time the turbine is in operation and shut down and provides an overview of the background noise in relation to the operating noise over the whole period of the measurement.

Non-normal background noises occurring in the measurement period, e.g. from aircraft or traffic, were marked during data acquisition to enable their easy omission in the evaluation to follow.

The state signal is used to differentiate between periods when the turbine is in operation and when it is stopped.

Following states have been used for evaluation in this report:

State 0: marks the data to be omitted in the evaluation,

State 0.5: depicts a stopped turbine,

State 1: depicts a turbine in operation.

In order to determine the wind speed at hub height during noise measurement of the turbine the allowed range of the power curve is taken into account based of the following equation:

$$(P_{k+1} - P_{tol}) - (P_k + P_{tol}) > 0 \quad (1)$$

where

k is the wind speed bin number of the power curve;

P_k is the power curve value at wind speed bin k ;

P_{k+1} is the power curve value above wind speed bin k ;

P_{tol} is the tolerance on the power reading, in this case it is 1 % of maximum power.

All data points which exceed or are below these limitations are determined with nacelle anemometer and the wind speed from the power curve using the following relation:

$$V_{nac,n} = \kappa_{nac} \cdot V_{nac,m} \quad (2)$$

where

$V_{nac,n}$ is the normalised wind speed from the nacelle anemometer, corrected to hub height;

$V_{nac,m}$ is the wind speed measured with the nacelle anemometer.

Outside the allowed range of the power curve the normalised WS at hub height is $V_{H,n} = V_{nac,n}$.

For this measurement κ_{nac} is determined to be $\kappa_{nac} = 1.01$.

For background noise measurements the wind speed is measured at hub height, corrected to a height of 10 m and furthermore multiplied by another K_z factor to calculate the normalised wind speed.

$$V_{B,n} = \kappa_z \cdot V_{Z,m} \quad (3)$$

where

$V_{Z,m}$ is the wind speed measured with an anemometer at height Z of at least 10 m;

$V_{B,n}$ is the normalised wind speed at hub height.

During background noise measurements: $V_{H,n} = V_{B,n}$.

For this measurement κ_z is determined to be $\kappa_z = 1.14$.

Besides the equivalent noise level, a 1/3-octave spectrum with centre frequencies between 20 Hz and 10 kHz is calculated from the recorded WAV files and later on is used for the evaluation of the equivalent noise level $L_{Aeq,o,j}$.

$$L_{Aeq,o,j} = 10 \cdot \log \sum_{i=1}^{28} 10^{\left(\frac{L_{Aeq,i,j}}{10}\right)} \quad (4)$$

$$\Delta_j = L_{Aeq,j} - L_{Aeq,o,j} \quad (5)$$

The difference Δ_j between the noise level and the sum of the 1/3-octave band spectrum is added to each individual band $L_{Aeq,n,i,j}$ in the 1/3-octave band spectrum for each measurement period j.

$$L_{Aeq,n,i,j} = L_{Aeq,i,j} + \Delta_j \quad (6)$$

4.3 Sound power level

In accordance to /1/ the corrected sound pressure level for the 1/3-octave band i is the energetic difference between the total noise level and the background noise level expressed as:

$$L_{V,c,i,k} = 10 \cdot \log \left(10^{0.1 L_{V,t,i,k}} - 10^{0.1 L_{V,b,i,k}} \right) \quad (7)$$

The corresponding sound power level $L_{WA,i,k}$ is calculated from the background corrected sound pressure level for the same 1/3-octave band as follows:

$$L_{WA,i,k} = L_{V,c,i,k} - 6 + 10 \cdot \lg \left(\frac{4 \cdot \pi \cdot R_1^2}{S_0} \right) \quad (8)$$

where 6 dB is the correction due to the doubled sound pressure sensed by the microphone caused by the coherent interference at the acoustically hard board.

$10 \cdot \lg \left(\frac{4 \cdot \pi \cdot R_1^2}{S_0} \right)$ corresponds to the ratio in dB of the surface area of a sphere having the radius R_1 to

the reference surface area of S_0

where

$$S_0 = 1 \text{ m}^2$$

$$R_1 = \sqrt{(R_0 + d)^2 + (H - h_A)^2} \quad (9)$$

The total sound power level $L_{WA,k}$ of the turbine in dB in wind speed bin k is derived by energy summing all the 1/3-octave band sound power levels:

$$L_{WA,k} = 10 \cdot \log \sum_{i=1}^{28} 10^{\left(\frac{L_{WA,i,k}}{10}\right)} \quad (10)$$

The difference between the sum of the 1/3-octave bands of the total noise and the sum of the 1/3-octave band of the background noise has to be at least 3 dB. Otherwise the result shall not be reported. If the difference is larger than 3 dB and smaller than 6 dB the result shall be marked with an asterisk.

The following results are given in the annex:

- A plot of $L_{T,c,l,k}$ and $L_{v,B,l,k}$ against wind speed;
- A plot of L_{Aeq} against power;
- A plot of rotor speed against power;
- A plot of met mast wind speed against wind speed from power curve;
- A plot of nacelle wind speed against wind speed from power curve;
- A time plot of the measurement.

For the Vestas V150-4.2 MW 50 Hz in the present configuration the apparent sound power levels are given in Table 6-1.

4.4 Tonal and frequency analysis

In accordance with the international standard /1/ a tonal analysis is carried out. The frequency spectrum of the noise measured on the acoustically hard board is determined on the basis of a narrow band analysis. This analysis is performed after the measurements using the recorded audio signal.

The results of the tonal analysis of the Vestas V150-4.2 MW 50 Hz according to /1/ are given in Table 6-1.

4.5 One-third octave analysis

The A-weighted sound spectra at all the wind speed bins are given in the annex.

4.6 Uncertainties

4.6.1 Type B uncertainties

For these measurements all the type B measurement uncertainty components as specified in the international standard /1/ are given in Table 4-1. For all of the type B uncertainties mentioned here, a rectangular distribution of possible values is assumed for simplicity with a range described as " $\pm a$ ". The standard deviation for such a distribution is

$$U = \frac{a}{\sqrt{3}} \quad (11)$$

Table 4-1 Type B measurement uncertainty components

| Parameter | Value |
|--|-------------------------------------|
| Calibration, U_{B1} | 0.2 dB |
| Instruments, U_{B2} | Taken from calibration certificates |
| Board, U_{B3} | 0.3 dB |
| Wind screen insertion loss, U_{B4} | Depending on the frequency |
| Distance and direction of microphone, U_{B5} | 0.1 dB |
| Air absorption, U_{B6} | Usually no uncertainty assumption |
| Weather, U_{B7} | 0.5 dB |
| Wind speed (measured), $U_{B8}^{1)}$ | 0.7 m/s |
| Wind speed (derived), $U_{B8}^{2)}$ | 0.2 m/s |
| Wind speed from power curve, U_{B9} | 0.2 m/s |

1) through nacelle anemometer or met mast

2) through power curve

4.6.2 Uncertainty on the wind speed

Before calculating the sound power level uncertainty, the uncertainty on the average wind speed per bin needs to be considered. Specifications are given in the international standard /1/.

The values per bin shall be averaged arithmetically as:

$$\bar{V}_k = \frac{1}{N} \cdot \sum_{j=1}^N V_{j,k} \quad (12)$$

where

N is the number of measurements in wind speed bin k ;

$V_{j,k}$ is the average value of the wind speed at measurement period j in wind speed bin k .

The type A uncertainty on the average wind speed in the k -th bin is calculated as:

$$s_{V,k} = \sqrt{\frac{\sum_{j=1}^N (V_{j,k} - \bar{V}_k)^2}{N \cdot (N - 1)}} \quad (13)$$

where

$V_{j,k}$ is the average value of the wind speed at measurement period j ;

\bar{V}_k is the average wind speed in the wind-speed bin k .

The type B uncertainty on the wind speed u_{V_j} for each measurement period j is calculated as:

$$u_{V_j} = \sqrt{\sum_{q=8}^9 u_{V_{j,q}}^2} \quad (14)$$

Where $u_{V_{j,q}}$ is the type B uncertainty due to the source q on the average wind speed for each measurement period j . Information about the sources are given in Table 4-1.

The type B uncertainty $u_{V,k}$ on the average wind speed bin k is calculated as:

$$u_{V,k} = \sqrt{\frac{1}{N} \cdot \sum_{j=1}^N u_{V_j}^2} \quad (15)$$

The combined uncertainty $u_{com,V,k}$ can be expressed as:

$$u_{com,V,k} = \sqrt{s_{V,k}^2 + u_{V,k}^2} \quad (16)$$

4.6.3 Uncertainty on the average sound spectra

For each 1/3-octave band i the average sound pressure level is energetically averaged as:

$$\bar{L}_{i,k} = 10 \cdot \log \left[\frac{1}{N} \cdot \sum_{j=1}^N 10^{\left(\frac{L_{i,j,k}}{10}\right)} \right] \quad (17)$$

where

N is the number of measurements in the wind speed bin k;

$L_{i,j,k}$ is the sound pressure level of the 1/3-octave band i in the measurement period j and in wind speed bin k.

The type A uncertainty on the uncertainty on the sound pressure level measured in the wind-speed bin k is calculated as:

$$s_{L_{i,k}} = \sqrt{\frac{\sum_{j=1}^N (L_{i,j,k} - \bar{L}_{i,k})^2}{N \cdot (N-1)}} \quad (18)$$

where

$\bar{L}_{i,k}$ is the average sound pressure spectrum in the wind speed bin k

The type B uncertainty on the energy averaged sound pressure level of the i-th 1/3-octave band for each measurement period j is calculated as:

$$u_{L_{i,j}} = \sqrt{\sum_{q=1}^7 u_{L_{i,j,q}}^2} \quad (19)$$

where

$u_{L_{i,j,q}}$ is the type B uncertainty from source q on the average sound pressure level of the 1/3-octave band for each measurement period j.

The type B uncertainty on the average sound pressure level of the 1/3-octave band i in wind speed bin k is calculated as:

$$u_{L_{i,k}} = \sqrt{\frac{1}{N} \cdot \sum_{j=1}^N u_{L_{i,j,k}}^2} = u_{L_{i,j,k}} \quad (20)$$

The combined uncertainty can be expressed as:

$$u_{com,L_i,k} = \sqrt{s_{L_i,k}^2 + u_{L_i,k}^2} \quad (21)$$

4.6.4 Uncertainty on the noise levels at bin centres

The sound pressure level for both total noise and background noise at bin centre is calculated at each 1/3- octave band i and at every bin centre of the wind speed k . Using linear interpolation the estimated sound pressure level at wind speed v is given as:

$$L_v(t) = (1-t) \cdot \bar{L}_k + t \cdot \bar{L}_{k+1} \quad (22)$$

Where $\bar{V}_k \leq V < \bar{V}_{k+1}$

The t value at a certain wind speed v is given as:

$$t = \frac{(V - \bar{V}_k)}{(\bar{V}_{k+1} - \bar{V}_k)} \quad (23)$$

To fulfil an entire statistical evaluation according to the /1/ a corresponding covariance is calculated as:

$$\text{cov}_{L_v,j,k} = \frac{1}{N-1} \cdot \sum_{j=1}^N (V_{j,k} - \bar{V}_k) \cdot (L_{i,j,k} - \bar{L}_{i,k}) \quad (24)$$

The corresponding covariance is used to calculate the uncertainty on the sound pressure level at the wind-speed bin centre v by using:

$$u_{L_v}(t) = \sqrt{u_L^2(t) - \frac{\text{cov}_{L_v}^2(t)}{u_v^2(t)}} \quad (25)$$

where

$$u_L^2(t) = (1-t)^2 \cdot u_{com,L,k}^2 + t^2 \cdot u_{com,L,k+1}^2$$

$$u_v^2(t) = (1-t)^2 \cdot u_{com,v,k}^2 + t^2 \cdot u_{com,v,k+1}^2$$

$$\text{cov}_{L_v}(t) = (1-t)^2 \cdot \frac{\text{cov}_{L_v,k}}{N_k} + t^2 \cdot \frac{\text{cov}_{L_v,k+1}}{N_{k+1}}$$

N_k is the number of measurements in the wind speed bin k

4.6.5 Uncertainty on the total noise level

If the difference between the total noise level and the background level is higher than 3 dB in the same 1/3- octave band i , the standard deviation of the background-corrected sound-pressure-levels is calculated as follows:

$$u_{c,i,k} = \frac{\sqrt{(u_{L_v,T,i} \cdot 10^{0.1L_{v,T,i}})^2 + (u_{L_v,B,i} \cdot 10^{0.1L_{v,B,i}})^2}}{10^{0.1L_{v,T,i}} - 10^{0.1L_{v,B,i}}} \quad (26)$$

If the difference between the total noise level and the background level is less than 3 dB in the same 1/3- octave band i , a 3 dB correction is applied and the result is marked with brackets []. The corresponding uncertainty is then calculated, as if the background noise level is 3 dB smaller than the total noise level $L_{v,B,i} = L_{v,T,i} - 3$ dB:

$$u_{c,i,k} = \frac{\sqrt{(u_{L_V,T,i} \cdot 10^{0.1L_{V,T,i}})^2 + (u_{L_V,B,i} \cdot 10^{0.1L_{V,T,i}-3})^2}}{10^{0.1L_{V,T,i}} - 10^{0.1(L_{V,T,i}-3)}} \quad (27)$$

4.6.6 Sound power level

The result of the sound power level measurement is subject to uncertainties which are due to the environment, meteorological conditions and the measurement system as calculated in the previous chapters.

There is the assumption all 1/3-octave bands are correlated. Therefore the uncertainty of the sound power level can be expressed as:

$$u_{L_{WA,k}} = \frac{\sum_{i=1}^{28} (u_{c,i,k} \cdot 10^{(0.1L_{WA,i,k})})}{\sum_{i=1}^{28} 10^{(0.1L_{WA,i,k})}} \quad (28)$$

The result of $u_{L_{WA,k}}$ will be shown in the annex.

4.6.7 Uncertainty on the tonality analysis

The uncertainty in the tonality is given in the annex for all the given tones.

5 DEVIATIONS

There are no deviations from the standard.

6 CONCLUSIONS

As ordered by Vestas Wind Systems A/S GL Garrad Hassan Deutschland GmbH took measurements of the acoustic noise emissions on the WTGS Vestas V150-4.2 MW 50 Hz with a hub height of 137 m.

All measurements and analysis of the sound power level and tonality described in this report based on the international standard /1/. The analysis of the sound power level was carried out using the standardised wind speed which was derived from the certified, measured power curve provided by the customer (see annex).

The result of this measurement is given in Table 6-1. For detailed results please refer to the annex.

For the measured turbine in PO1 the relevant wind range according to /1/ is between 7.3 m/s and 11.9 m/s.

Table 6-1 Summary of results at hub height

| WS at hub height [m/s] | SPL $L_{WA,k}$ [dB] | Combined uncertainty in the SPL $U_{C,L,WA,k}$ [dB] | Audible tone? ¹⁾ | Tonal audibility $\Delta L_{a,k}$ [dB] | Frequency of the most prevalent tone [Hz] |
|------------------------|---------------------|---|-----------------------------|--|---|
| 7.5 | 102.0 | 1.2 | Yes | 0.52 | 126 |
| 8.0 | 103.3 | 1.1 | No | -2.09 | 134 |
| 8.5 | 104.3 | 0.8 | No | -2.43 | 140 |
| 9.0 | 104.7 | 0.7 | No | -2.97 | 142 |
| 9.5 | 104.7 | 0.6 | - | - | - |
| 10.0 | 104.8 | 0.7 | - | - | - |
| 10.5 | 104.7 | 0.7 | No | -2.16 | 143 |
| 11.0 | 104.6 | 0.7 | No | -1.66 | 144 |
| 11.5 | 104.5 | 0.7 | No | -1.11 | 143 |
| 12.0 | 104.3 | 0.7 | No | -1.62 | 144 |
| 12.5 | 104.5 | 0.8 | No | -0.98 | 143 |
| 13.0 | 104.6 | 0.8 | No | -1.93 | 144 |
| 13.5 | 104.5 | 0.7 | No | -1.74 | 143 |
| 14.0 | 104.8 | 0.8 | No | -1.70 | 143 |

¹⁾ Per /1/ section 9.5.8 a tone is audible if tone is *relevant* and $\Delta L_{a,k} \geq 0$ dB.

Table 6-2 Summary of results at 10 m height

| WS at 10 m height [m/s] | SPL $L_{WA,10m,k}$ [dB] | Combined uncertainty in the SPL $U_{C,L,WA,10m,k}$ [dB] |
|-------------------------|-------------------------|---|
| 5 | 101.9 | 1.1 |
| 6 | 104.7 | 0.6 |
| 7 | 104.7 | 0.7 |
| 8 | 104.3 | 0.7 |
| 9 | 104.5 | 0.7 |

It is assured that this report has been drawn up impartially and with best knowledge and conscience.

7 REFERENCES

- /1/ IEC 61400-11 Ed. 3.0 Wind Turbines,
Part 11: Acoustic Noise Measurement Techniques
2012-11-07
- /2/ ISI-RA-MEA-4601
Noise emission measurements on wind turbines – one third octave level method
2017-03-01
This document is part of the management system of the GL Garrad Hassan Deutschland GmbH.
It is possible to view this document at GH-D.
- /3/ ISI-RA-MEA-2501
Calibration Programs
2017-06-22
This document is part of the quality management documentation of the GL Garrad Hassan
Deutschland GmbH. It is possible to view this document at GH-D.

8 LIST OF ABBREVIATIONS


| Abbreviation | Description | Unit |
|---------------------|---|-------|
| d | distance from rotor centre to tower axis | [m] |
| D | rotor diameter | [m] |
| H | height of rotor centre above local ground near the wind turbine | [m] |
| L_A or L_C | A or C-weighted sound pressure level | [dB] |
| L_{Aeq} | equivalent continuous A-weighted sound pressure level | [dB] |
| $L_{pn,j,k}$ | sound pressure level of masking noise within a critical band in the ' j^{th} ' spectrum at the ' k^{th} ' wind speed bin | [dB] |
| $L_{pn,avg,j,k}$ | average of analysis bandwidth sound pressure levels of masking noise in the ' j^{th} ' spectra at the ' k^{th} ' wind speed bin | [dB] |
| $L_{pt,j,k}$ | sound pressure level of the tone or tones in the ' j^{th} ' spectra at the ' k^{th} ' wind speed bin | [dB] |
| $L_{WA,k}$ | apparent sound power level, where k is a wind speed centre value | [dB] |
| log | logarithm to base 10 | |
| P_m | measured electric power | [kW] |
| P_n | normalised electric power | [kW] |
| P_k | power curve value at wind bin k | [kW] |
| P_{tol} | tolerance of the power reading | [kW] |
| R_0 | reference distance | [m] |
| R_1 | slant distance from rotor centre to actual measurement position | [m] |
| S_0 | reference area, $S_0 = 1 \text{ m}^2$ | [m] |
| SPL | sound power level | [dB] |
| T_C | air temperature | [°C] |
| T_K | absolute air temperature | [K] |
| u_A | Uncertainty components of Type A | [dB] |
| u_B | Uncertainty components of Type B | [dB] |
| $V_{H,n}$ | normalised wind speed at hub height H | [m/s] |
| $V_{P,n}$ | normalised wind speed derived from power curve | [m/s] |
| V_z | wind speed at height z | [m/s] |
| $V_{nac,m}$ | measured wind speed from nacelle anemometer | [m/s] |
| $V_{nac,n}$ | normalised wind speed from nacelle anemometer | [m/s] |
| f | frequency of the tone | [Hz] |
| f_c | centre frequency of critical band | [Hz] |
| p | atmospheric pressure | [kPa] |
| z_0 | roughness length | [m] |
| z_{0ref} | reference roughness length, 0.05 m | [m] |
| z | anemometer height | [m] |
| κ | Ratio between normalised wind speed and measured wind speed | [-] |
| $\Delta L_{tn,j,k}$ | tonality of the ' j^{th} ' spectrum at ' k^{th} ' wind speed | [dB] |
| ϕ | inclination angle | [°] |
| $V_{z,m}$ | is the measured wind speed with an anemometer at height Z of at least 10 m | [m/s] |
| $V_{B,n}$ | is the normalised wind speed at hub height | [m/s] |

Description of the subscripts and indexes of the formulas


| | |
|-----|--|
| i | 1/3 octave band number (e.g. $i = 1$ for 20 Hz centre frequency, $i = 2$ for 25 Hz centre frequency, ... , $i = 28$ for 10 kHz centre frequency) |
| j | 10 s measurement period number (each bin should have the minimum of 10 points per bin therefore $j = 1$ to 10 or greater) |
| k | wind speed bin (i.e. $k = 6$ m/s bin, $k = 6,5$ m/s bin, $k = 7$ m/s bin, etc.) |
| V | bin centre value; of measured 1/3 octave spectrum |
| n | normalized spectrum |
| N | number of measurements in wind speed k |
| T | total noise |
| B | background noise |
| C | background corrected total noise |

9 APPENDIX

9.1 L_{Aeq} vs. wind speed at hub height



9.2 Summary of the results according to hub height




Site / Standort: Østerild (Denmark)
 WTGS-SNo. / WEA-SNr.: 228051
 Mode / Modus: PO1
 Date of meas./ Messdatum: 2019-06-26
 Standard / Messung: IEC 61400-11 Ed.3
 Project-No. / Projekt-Nr.: 10163788
 In charge / Bearbeiter: Annika Johannsen


Vestas V150-4.2 MW 50 Hz
 Results relating to hub height
 Ergebnisse bezogen auf Nabenhöhe




9.3 L_{Aeq} vs. wind speed at 10 m height




9.4 Summary of the results according to 10 m height




9.5 Measured wind speed at 10 m height vs. wind speed from power curve




9.6 Measured wind speed at hub height vs. wind speed from power curve




9.7 L_{Aeq} vs. active power




9.8 Rotor speed vs. active power




9.9 Rotor speed vs. wind speed at hub height




9.10 Time plot of measurement (page 1)




9.11 Time plot of measurement (page 2)




9.12 Time plot of measurement (page 3)




9.13 Third-octave sound power spectra at a WS of 7.5 m/s at hub height




9.14 Third-octave sound power spectra at a WS of 8.0 m/s at hub height




9.15 Third-octave sound power spectra at a WS of 8.5 m/s at hub height




9.16 Third-octave sound power spectra at a WS of 9.0 m/s at hub height




9.17 Third-octave sound power spectra at a WS of 9.5 m/s at hub height




9.18 Third-octave sound power spectra at a WS of 10.0 m/s at hub height




9.19 Third-octave sound power spectra at a WS of 10.5 m/s at hub height




9.20 Third-octave sound power spectra at a WS of 11.0 m/s at hub height




9.21 Third-octave sound power spectra at a WS of 11.5 m/s at hub height




9.22 Third-octave sound power spectra at a WS of 12.0 m/s at hub height




9.23 Third-octave sound power spectra at a WS of 12.5 m/s at hub height



9.24 Third-octave sound power spectra at a WS of 13.0 m/s at hub height




9.25 Third-octave sound power spectra at a WS of 13.5 m/s at hub height




Created by DNV GL Acoustic Tools version 18.0.11




9.26 Third-octave sound power spectra at a WS of 14.0 m/s at hub height




9.27 Third-octave sound power spectra at a WS of 5 m/s at 10 m height



9.28 Third-octave sound power spectra at a WS of 6 m/s at 10 m height




9.29 Third-octave sound power spectra at a WS of 7 m/s at 10 m height




Bin 7 Vestas V150-4.2 MW 50 Hz
 One third octave analysis at 10 m height
 Terzanalyse bezogen auf 10 m Höhe




9.30 Third-octave sound power spectra at a WS of 8 m/s at 10 m height




9.31 Third-octave sound power spectra at a WS of 9 m/s at 10 m height




9.32 Tonality analysis - $\Delta L_{pn,j}$ and $\Delta L_{a,k}$ vs. frequency




9.33 Tonality analysis - rpm vs. frequency for the identified tones in the total noise (0-5000 Hz)




9.34 Tonality analysis - rpm vs. frequency for the identified tones in the total noise (40-600 Hz)




9.35 Tonality analysis - wind bin overview (page 1)




9.36 Tonality analysis - wind bin overview (page 2)




9.37 Tonality analysis - wind bin overview (page 3)




9.38 Tonality analysis - wind bin overview (page 4)




9.39 Frequency spectra of total and background noise at a WS of 7.5 m/s at hub height




9.40 Frequency spectra of total and background noise at a WS of 8.0 m/s at hub height




9.41 Frequency spectra of total and background noise at a WS of 8.5 m/s at hub height




9.42 Frequency spectra of total and background noise at a WS of 9.0 m/s at hub height




9.43 Frequency spectra of total and background noise at a WS of 9.5 m/s at hub height




9.44 Frequency spectra of total and background noise at a WS of 10.0 m/s at hub height




9.45 Frequency spectra of total and background noise at a WS of 10.5 m/s at hub height




9.46 Frequency spectra of total and background noise at a WS of 11.0 m/s at hub height




9.47 Frequency spectra of total and background noise at a WS of 11.5 m/s at hub height




9.48 Frequency spectra of total and background noise at a WS of 12.0 m/s at hub height




9.49 Frequency spectra of total and background noise at a WS of 12.5 m/s at hub height




9.50 Frequency spectra of total and background noise at a WS of 13.0 m/s at hub height



9.51 Frequency spectra of total and background noise at a WS of 13.5 m/s at hub height



9.52 Frequency spectra of total and background noise at a WS of 14.0 m/s at hub height



9.53 Power curve used for the analysis

RESTRICTED

Document no.: 0067-7067 V09
 Document owner: Platform Management
 Type: T05 - General Description

Performance Specification V150-4.0/4.2 MW 50/60 Hz
 Power Curves, Ct Values and Sound Curves, Power
 Optimized Mode PO1/PO1-0S

Date: 2018-09-25
 Restricted
 Page 15 of 41

7 Power Curves, Ct Values and Sound Curves, Power Optimized Mode PO1/PO1-0S


7.1 Power Curves, Power Optimized Mode PO1/PO1-0S

| Air density [kg/m ³] | | | | | | | | | | | | | | |
|----------------------------------|-------|------|-------|------|-------|------|-------|------|-------|------|-------|------|------|-------|
| Wind speed [m/s] | 1.225 | 0.95 | 0.975 | 1.0 | 1.025 | 1.05 | 1.075 | 1.1 | 1.125 | 1.15 | 1.175 | 1.2 | 1.25 | 1.275 |
| 3.0 | 81 | 51 | 54 | 57 | 60 | 62 | 65 | 68 | 70 | 73 | 76 | 79 | 84 | 87 |
| 3.5 | 172 | 123 | 127 | 132 | 136 | 141 | 145 | 150 | 154 | 159 | 163 | 168 | 177 | 181 |
| 4.0 | 285 | 210 | 217 | 224 | 231 | 238 | 244 | 251 | 258 | 265 | 272 | 278 | 292 | 299 |
| 4.5 | 424 | 318 | 328 | 337 | 347 | 357 | 366 | 376 | 386 | 395 | 405 | 415 | 434 | 444 |
| 5.0 | 597 | 452 | 465 | 478 | 492 | 505 | 518 | 531 | 544 | 557 | 571 | 584 | 610 | 623 |
| 5.5 | 809 | 616 | 633 | 651 | 669 | 686 | 704 | 721 | 739 | 757 | 774 | 792 | 827 | 844 |
| 6.0 | 1062 | 813 | 835 | 858 | 881 | 904 | 926 | 949 | 972 | 995 | 1017 | 1040 | 1085 | 1108 |
| 6.5 | 1361 | 1045 | 1074 | 1103 | 1131 | 1160 | 1189 | 1218 | 1247 | 1275 | 1304 | 1332 | 1389 | 1418 |
| 7.0 | 1709 | 1317 | 1353 | 1389 | 1425 | 1461 | 1496 | 1532 | 1568 | 1603 | 1639 | 1674 | 1744 | 1779 |
| 7.5 | 2101 | 1628 | 1671 | 1715 | 1758 | 1802 | 1845 | 1888 | 1931 | 1974 | 2016 | 2058 | 2143 | 2185 |
| 8.0 | 2545 | 1982 | 2034 | 2086 | 2137 | 2189 | 2240 | 2292 | 2343 | 2394 | 2444 | 2494 | 2594 | 2644 |
| 8.5 | 3014 | 2375 | 2435 | 2496 | 2556 | 2616 | 2674 | 2732 | 2790 | 2848 | 2904 | 2959 | 3067 | 3120 |
| 9.0 | 3458 | 2791 | 2856 | 2921 | 2986 | 3052 | 3112 | 3172 | 3232 | 3292 | 3348 | 3403 | 3510 | 3562 |
| 9.5 | 3807 | 3180 | 3246 | 3312 | 3377 | 3443 | 3499 | 3556 | 3613 | 3669 | 3715 | 3761 | 3845 | 3884 |
| 10.0 | 4038 | 3543 | 3602 | 3662 | 3722 | 3781 | 3824 | 3866 | 3909 | 3951 | 3980 | 4009 | 4059 | 4079 |
| 10.5 | 4143 | 3842 | 3884 | 3926 | 3969 | 4012 | 4035 | 4059 | 4083 | 4107 | 4119 | 4131 | 4150 | 4158 |
| 11.0 | 4191 | 4055 | 4078 | 4100 | 4122 | 4145 | 4154 | 4162 | 4171 | 4180 | 4184 | 4187 | 4193 | 4195 |
| 11.5 | 4199 | 4152 | 4160 | 4168 | 4176 | 4185 | 4188 | 4190 | 4193 | 4196 | 4197 | 4198 | 4199 | 4200 |
| 12.0 | 4200 | 4185 | 4188 | 4191 | 4194 | 4198 | 4198 | 4199 | 4199 | 4200 | 4200 | 4200 | 4200 | 4200 |
| 12.5 | 4200 | 4197 | 4197 | 4198 | 4199 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 |
| 13.0 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 |
| 13.5 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 |
| 14.0 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 |
| 14.5 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 |
| 15.0 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 |
| 15.5 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 |
| 16.0 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 |
| 16.5 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 |
| 17.0 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 |
| 17.5 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 |
| 18.0 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 |
| 18.5 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 |
| 19.0 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 |
| 19.5 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 |
| 20.0 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 | 4200 |
| 20.5 | 4186 | 4186 | 4186 | 4186 | 4186 | 4186 | 4186 | 4186 | 4186 | 4186 | 4186 | 4186 | 4186 | 4186 |
| 21.0 | 3870 | 3870 | 3870 | 3870 | 3870 | 3870 | 3870 | 3870 | 3870 | 3870 | 3870 | 3870 | 3870 | 3870 |
| 21.5 | 3373 | 3373 | 3373 | 3373 | 3373 | 3373 | 3373 | 3373 | 3373 | 3373 | 3373 | 3373 | 3373 | 3373 |
| 22.0 | 2745 | 2745 | 2745 | 2745 | 2745 | 2745 | 2745 | 2745 | 2745 | 2745 | 2745 | 2745 | 2745 | 2744 |
| 22.5 | 2154 | 2154 | 2154 | 2154 | 2154 | 2154 | 2154 | 2154 | 2154 | 2154 | 2154 | 2154 | 2154 | 2154 |
| 23.0 | 1805 | 1805 | 1805 | 1805 | 1805 | 1805 | 1805 | 1805 | 1805 | 1805 | 1805 | 1805 | 1805 | 1805 |
| 23.5 | 1526 | 1526 | 1526 | 1526 | 1526 | 1526 | 1526 | 1526 | 1526 | 1526 | 1526 | 1526 | 1526 | 1526 |
| 24.0 | 1283 | 1283 | 1283 | 1283 | 1283 | 1283 | 1283 | 1283 | 1283 | 1283 | 1283 | 1283 | 1283 | 1283 |
| 24.5 | 1116 | 1116 | 1116 | 1116 | 1116 | 1116 | 1116 | 1116 | 1116 | 1116 | 1116 | 1116 | 1116 | 1116 |

Table 7-1: Power curve, Power Optimized Mode PO1/PO1-0S

9.54 Manufacturer's certificate (page 1)

CONFIDENTIAL

| | |
|--|---|
| Herstellerbescheinigung zu spezifischen Daten einer WEA vom Typ: |  |
| Manufacturer's certificate on specific data of a WT of the type of installation: | |
| V150-4.2 MW, PO1 in Østerild, Denmark | |

DMS: 0079-5470-V01

| 1 Allgemeines | | General | |
|--|--|----------------|---|
| 1 Hersteller | Vestas Wind Systems A/S | | manufacturer |
| 2 Anlagenbezeichnung | V150-4.2 MW 50 Hz | | type name |
| 3 Art (horizontale/vertikale Achse) | HAWT | | generic type (horizontal axis /vertical axis) |
| 4 Nennleistung | 4200 | kW | rated power |
| 5 Nennspannung | 720 (LV side) | V | rated voltage |
| 6 Nabenhöhe über Grund | 137 | m | hub height above ground |
| 7 Nabenhöhe über Fundamentflansch | - | m | hub height above top of foundation flange |
| 8 Nennwindgeschwindigkeit | 10,1 | m/s | rated wind speed (steady wind speed) |
| 9 Ein- und Abschaltwindgeschwindigkeit | 3/24.5 | m/s | cut-in and cut-out wind speed |
| 10 Beitrag zum Stoßkurzschlussstrom | 4,5 | kA | contribution to short circuit current |
| 2 Rotor | | Rotor | |
| 1 Durchmesser | 150 | m | diameter |
| 2 Bestrichene Fläche | 17671 | m ² | swept area |
| 3 Anzahl der Blätter | 3 | | number of blades |
| 4 Nabenart (pendelnd/starr) | rigid | | generic type of hub (teetered/rigid) |
| 5 Anordnung zum Turm (luv/lee) | luv | | relative position to tower (luv/lee) |
| 6 Nennzahl / -bereich | 10,37 | 1/min / rpm | rated speed / speed range |
| 7 Auslegungsschnellaufzahl | 9,35 | | design tip speed ratio |
| 8 Rotorblatteinstellwinkel | -10 to 95 | ° | rotor blade pitch setting |
| 9 Konuswinkel | 5,5 | ° | cone angle |
| 10 Achsneigung | 6 | ° | tilt angle |
| 11 Abstand Rotorflanschmittelpunkt und Turmmittellinie | 4,5 | m | distance between rotor flange centre and tower centre line |
| 3 Rotorblatt | | Rotor blade | |
| 1 Hersteller | Vestas Wind Systems A/S | | manufacturer |
| 2 Typenbezeichnung | Vestas 73.65m | | type name |
| 3 Profile innen/außen | Infused structural airfoil shell | | blade section inner/outer |
| 4 Material | Fibreglass reinforced epoxy, carbon fibres and Solid Metal Tip (SMT) | | material |
| 5 Länge | 73,65 | m | length |
| 6 Profiltiefe max./min. | 4,2 / - | m | chord length (max./min.) |
| 7 Zusatzkomponenten (z. B. stall strips, Vortex-Generatoren, Turbulatoren) | Serrated Trailing Edges | | additional components (e.g. stall strips, vortex generators, trip strips) |
| 8 Extenderlänge | n/a | m | extender length |
| 4 Getriebe | | Gear | |
| 1 Hersteller | ZF | | manufacturer |
| 2 Typenbezeichnung | EH1052A | | type |
| 3 Ausführung | 2 planetary + 1 helical stage | | design |
| 4 Übersetzungsverhältnis | i = 143.37 | | gear ratio |
| 5 Generator | | Generator | |
| 1 Hersteller | Vestas | | manufacturer |
| 2 Typenbezeichnung | 3 Phase IG, VND DASG 560/6M | | type |
| 3 Anzahl | 1 | | numbers |
| 4 Art (horizontale/vertikale Achse) | horizontal | | design |
| 5 Nennleistung (en) | 4450 | kW | rated power (s) |
| 6 Nennscheinleistung | 5057 | kVA | rated apparent power |
| 7 Nennzahlen oder Drehzahlbereich | 1485 | 1/min / rpm | rated speed (s) / speed range |
| 8 Spannung | 800 (at rated speed) | V | voltage |
| 9 Frequenz | 74 | Hz | frequency |
| 10 Nennschlupf | 0,54 | % | rated slip |

PO2 0079-5470 Ver 01 - Approved- Exported from DMS: 2019-08-13 by NCN


VESTAS PROPRIETARY NOTICE. This document contains valuable confidential information of Vestas Wind Systems A/S. It is protected by copyright law as an industrial work. Vestas reserves all patent, copyright, trade secret, and other proprietary rights to it. The information in this document may not be used, reproduced, or disclosed except if and to the extent rights are expressly granted by Vestas in writing and subject to applicable conditions. Vestas disclaims all warranties except as expressly granted by written agreement and is not responsible for unauthorized uses, for which it may pursue legal remedies against responsible parties.

Classification: Restricted

Seite/Page: 1/5

9.55 Manufacturer's certificate (page 2)

CONFIDENTIAL

| | |
|--|---|
| Herstellerbescheinigung zu spezifischen Daten einer WEA vom Typ: |  |
| Manufacturer's certificate on specific data of a WT of the type of installation: | |
| V150-4.2 MW, PO1 in Østerild, Denmark | |

DMS: 0079-5470-V01

| 6 | Turm | Tower |
|----|--|--|
| 1 | Hersteller | Vestas Wind Systems A/S manufacturer |
| 2 | Typenbezeichnung | Tubular type |
| 3 | Ausführung (Gitter/Rohr, zyl./kon.) | Cylindrical/conical tubular design (lattice/tubular, cylindrical/conical) |
| 4 | Material | Steel material |
| 5 | Länge | 132,1 m length |
| 7 | Windrichtungsnachführung | Yaw control |
| 1 | Ausführung (aktiv/passiv) | Active design (active/passive) |
| 2 | Antriebsart (el./mech./hydr.) | Electrical drive (electr./mech./hydr.) |
| 3 | Dämpfungssystem während des Betriebs | Built-in friction damping system during operation |
| 8 | Betriebsführung /Regelung | Control system/control |
| 1 | Software version Nr. | 2019.06.26 software version No. |
| 2 | - Umrichter | - - converter |
| 3 | - Steuerung | - - control system |
| 4 | - Netzschutz | - - grid protection |
| 5 | - Andere relevante | - - others |
| 6 | Art der Leistungsregelung | Pitch & Variable speed generic type of power control |
| 7 | Antrieb der Leistungsregelung | - actuation of power control |
| 8 | Hersteller der Betriebsführung/Regelung | Vestas Wind Systems A/S manufacturer of control system |
| 9 | - Typenbezeichnung | System 8000 - VMGlobal - type |
| 10 | - Verwendete Steuerungskurve | - - applied control characteristic |
| 9 | Sonstige elektrische Komponenten | Other electric installations |
| 1 | N ₁₀ , Einschalten bei Einschaltwind | 10 N ₁₀ , start up at cut in wind speed |
| 2 | N ₁₂₀ , Einschalten bei Einschaltwind | 120 N ₁₂₀ , start up at cut in wind speed |
| 3 | N ₁₀ , Einschalten bei Nennwind | 1 N ₁₀ , start up at rated wind speed |
| 4 | N ₁₂₀ , Einschalten bei Nennwind | 12 N ₁₂₀ , start up at rated wind speed |
| 5 | N ₁₀ , Ausschalten bei Nennwind | 1 N ₁₀ , cut off at rated wind speed |
| 6 | N ₁₂₀ , Ausschalten bei Nennwind | 12 N ₁₂₀ , cut off at rated wind speed |
| 7 | N ₁₀ , Umschalten zwischen den Generatoren | n/a N ₁₀ , switching between generators |
| 8 | N ₁₂₀ , Umschalten zwischen den Generatoren | n/a N ₁₂₀ , switching between generators |
| 9 | Anzahl der Kompensationsstufen | n/a number of compensation stages |
| 10 | Blindleistung Stufe 1 | n/a kvar reactive power stage 1 |
| 11 | Blindleistung Stufe 2 | n/a kvar reactive power stage 2 |
| 12 | Blindleistung Stufe _ | n/a kvar reactive power stage _ |
| 13 | Blindleistung Stufe _ | n/a kvar reactive power stage _ |
| 14 | Art der Netzkopplung | Full Scale Converter generic type of interconnection |
| 15 | - Hersteller | Vestas Wind Systems A/S - manufacturer |
| 16 | - Typenbezeichnung | - - type |
| 17 | Netzschutzhersteller | Vestas Wind Systems A/S grid protection manufacturer |
| 18 | - Typenbezeichnung | VMP Global Tm - type |
| 19 | - Einstellbereiche | - - adjustment ranges |
| 20 | Spannungssteigerungsschutz | 792 V overvoltage protection |
| 21 | Spannungsrückgangsschutz | 648 V undervoltage protection |
| 22 | Frequenzsteigerungsschutz | 53 Hz overfrequency protection |
| 23 | Frequenzrückgangsschutz | 46,5 Hz underfrequency protection |
| 24 | Typenbezeichnung der Abschaltseinheit | Schneider - MTZ2-32 H10 circuit breaker type |
| 25 | Oberschwingungsfiter (ja/nein) (OS-Filter müssen auf den Netzverknüpfungspunkt ausgelegt sein) | yes (harmonic filter have to be designed for the point of common coupling) |


Classification: Restricted

Seite/Page: 2/5

VESTAS PROPRIETARY NOTICE

9.56 Manufacturer's certificate (page 3)

CONFIDENTIAL

| | | |
|--|--------------------------------|---|
| Herstellerbescheinigung zu spezifischen Daten einer WEA vom Typ: | |  |
| Manufacturer's certificate on specific data of a WT of the type of installation: | | |
| V150-4.2 MW, PO1 in Østerild, Denmark | | |
| DMS: 0079-5470-V01 | | |
| 10 | Umrichter | Converter |
| 1 | Hersteller | Vestas Wind Systems A/S converter manufacturer |
| 2 | Typenbezeichnung | Full quadrant IGBT converter type |
| 3 | Spannungsebene | 720 (Grid) / 800 (Generator) V voltage level |
| 4 | Nennscheinleistung | 5100 kVA converter apparent rated power |
| 11 | Transformator | Transformer |
| 1 | Hersteller | Siemens (s/n: K832736) transformer manufacturer |
| 2 | Typenbezeichnung | 4GY6781-1EY transformer type |
| 3 | Schaltgruppe | Dyn5 transformer connection |
| 4 | Nennscheinleistung | 5150 kVA transformer apparent rated power |
| 5 | Spannungsebenen | 36.0/1.1 kV voltage level |
| 6 | Kurzschlussspannung | 9,6 % short circuit voltage |
| 12 | Bremssystem | Brake system |
| 1 | Bremssystem (primär/sekundär) | aerodynamic (feathering) / mechanical brake system (primary/secondary) |
| 2 | - Aktivierung | hydraulic / mechanical - activation |
| 3 | - Anordnung zum Turm (luv/lee) | luv - location |
| 4 | - Bremsenart | aerodynamic / disc brake - type |
| 5 | - Bestätigung | Pause & Stop / Emergency Stop - actuation |
| 13 | Typenprüfung | Type test |
| 1 | Prüfbehörde | DNV-GL testing authority |
| 2 | Aktenzeichen | IEC 61400 reference |
| 14 | Informativer Teil | Informative |
| 1 | Standort der vermessenen WEA | Osterild (Denmark) location of measured WT |
| 2 | Koordinaten des Standortes | 57.066970, 8.884000 geographical coordinates of the location |
| 3 | Seriennummer | serial number of |
| 4 | - WEA | 228051 - WT |
| 5 | - Blätter | 29101054WHD213007 29101054WHD213012 29101054WHD213010 - blades |
| 6 | - Getriebe | EH1052A-001.P3/LM0001 - gearbox |
| 7 | - Generator | 635747 - generator |
| 8 | Netzkurzschlussleistung | 805,81 MVA short-circuit apparent power |
| 7 | Netzimpedanzwinkel | 87,96 ° network impedance phase angle |

Anschrift des Herstellers
Address of manufacturer

Vestas Wind System A/S
Hedeager 42
8200 Aarhus

Stempel, Unterschrift
stamp, signature



Der Hersteller der Windenergieanlage bestätigt, dass die WEA, deren elektrischen Eigenschaften in den Prüfberichten abgebildet sind, hinsichtlich ihrer technischen Daten mit den o.g. Positionen identisch ist.
The manufacturer of the wind turbine (WT) confirms that the WT whose power quality is measured and depicted in the test reports, is identical with the above entries with regard to it-s technical data

9.57 Measuring equipment

| Beschreibung <i>description</i> | Fabrikat <i>supplier</i> | Typ <i>type</i> | WT Nr./Ser.Nr. <i>WT stock number/ serial number</i> | letzte Kalibrierung <i>last calibration</i> | nächste Kalibrierung <i>next calibration</i> | letzte Eichung <i>last verification</i> | nächste Eichung <i>next verification</i> |
|--|---|--|---|--|--|---|---|
| Schallpegelmesser <i>sound level meter</i> | Svantek | 979 | GLGH 428616-337000021 (45290) | Sep- 17 | Sep- 19 | Jun- 19 | Dez- 21 |
| Mikrofon <i>microphone</i> | G.R.A.S. | 40AE | zu GLGH 428616-337000021 (240597) | gemeinsame Kalibration <i>common calibration</i> | gemeinsame Kalibration <i>common calibration</i> | gemeinsame Eichung <i>common verification</i> | gemeinsame Eichung <i>common verification</i> |
| Vorverstärker <i>preamp.</i> | Svantek | SV17 | zu GLGH 428616-337000021 (52127) | | | | |
| Mikrofonkabel <i>microphone cable</i> | Svantek | SC93/10 | zu GLGH 428616-337000021 | | | | |
| Akustischer Kalibrator <i>acoustic calibrator</i> | Brüel & Kjær | 4231 | GLGH 428604-333000006 (2438819) | Sep- 18 | Sep- 19 | | |
| Primärwindschirm <i>primary wind shield</i> | Brüel & Kjær | UA 0237 | - | | | | |
| Sekundärwindschirm <i>secondary wind shield</i> | DNVGL | EWS | 15- Okt | | | | |
| Anemometer <i>anemometer</i> | Thies Clima | 4.9201.00.000 | GLGH 428616-113000298 (06160031) | Sep- 18 | Sep- 20 | | |
| Windrichtungsgeber <i>wind direction sensor</i> | Thies Clima | 4.9201.00.000 | zu GLGH 428616-113000298 (06160031) | | | | |
| Temperaturgeber <i>temperature sensors</i> | Thies Clima | 4.9201.00.000 | zu GLGH 428616-113000298 (06160031) | | | | |
| Luftdruckgeber <i>pressure sensors</i> | Thies Clima | 4.9201.00.000 | zu GLGH 428616-113000298 (06160031) | | | | |
| Feuchtesensor <i>humidity sensor</i> | Thies Clima | 4.9201.00.000 | zu GLGH 428616-113000298 (06160031) | | | | |
| WEA Box | Expert | EX9017/F | GLGH 428616-323000008 (66007) | Jul- 18 | Jul- 20 | | |
| Laser- Entfernungsmesser <i>laser distance meter</i> | Bushnell Corporation | Yardage PRO 1000 | WT300087704 (027103) | Aug- 17 | Aug- 19 | | |
| Erfassungsrechner <i>data acquisition computer</i> | HP | Elitebook 2570P | GLGH 425515-41100383 (CNU343BB0N) | | | | |
| Erfassungs- und Auswertesoftware <i>data acquisition and analytical software</i> | GIS Aachen Microsoft DATALOG GmbH | DIAdem 2012/2018 Office 2016 Dasy-Lab 10.0 | | | | | |

9.58 Calibration certificate of noise level meter (page 1)



akkreditiert durch die / accredited by the
Deutsche Akkreditierungsstelle GmbH



Deutsche
Akkreditierungsstelle
D-K-15183-01-00

als Kalibrierlaboratorium im / as calibration laboratory in the

Deutschen Kalibrierdienst **DKD**

Kalibrierschein
Calibration Certificate

Kalibrierzeichen
Calibration mark

| |
|---------------------|
| 5 1 0 2 |
| D-K- 15183-01-00 |
| 2017-09 |

| | |
|--|---|
| Gegenstand <i>Object</i> | Schallpegelmesser |
| Hersteller <i>Manufacturer</i> | SVANTEK |
| Typ <i>Type</i> | SVAN 979 |
| Fabrikat/Serien-Nr. <i>Serial number</i> | 45290 |
| Auftraggeber <i>Customer</i> | GL Garrad Hassan Deutschland GmbH DE-25709 Kaiser-Wilhelm-Koog |
| Auftragsnummer <i>Order No.</i> | 171688 |
| Anzahl der Seiten des Kalibrierscheines <i>Number of pages of the certificate</i> | 7 |
| Datum der Kalibrierung <i>Date of calibration</i> | 27.09.2017 |

Dieser Kalibrierschein dokumentiert die Rückführung auf nationale Normale zur Darstellung der Einheiten in Übereinstimmung mit dem Internationalen Einheitensystem (SI). Die DAkkS ist Unterzeichner der multi-lateralen Übereinkommen der European co-operation for Accreditation (EA) und der International Laboratory Accreditation Cooperation (ILAC) zur gegenseitigen Anerkennung der Kalibrierscheine. Für die Einhaltung einer angemessenen Frist zur Wiederholung der Kalibrierung ist der Benutzer verantwortlich. *This calibration certificate documents the traceability to national standards, which realize the units of measurement according to the International System of Units (SI). The DAkkS is signatory to the multilateral agreements of the European co-operation for Accreditation (EA) and of the International Laboratory Accreditation Cooperation (ILAC) for the mutual recognition of calibration certificates. The user is obliged to have the object recalibrated at appropriate intervals.*

Dieser Kalibrierschein darf nur vollständig und unverändert weiterverbreitet werden. Auszüge oder Änderungen bedürfen der Genehmigung sowohl der Deutschen Akkreditierungsstelle GmbH als auch des ausstellenden Kalibrierlaboratoriums. Kalibrierscheine ohne Unterschrift haben keine Gültigkeit. *This calibration certificate may not be reproduced other than in full except with the permission of both the Deutsche Akkreditierungsstelle GmbH and the issuing laboratory. Calibration certificates without signature are not valid.*

| | | |
|----------------------|---|---------------------------------------|
| Datum <i>Date</i> | Stellv. Leiter des Kalibrierlaboratoriums <i>Deputy head of the calibration laboratory</i> | Bearbeiter <i>Person in charge</i> |
|----------------------|---|---------------------------------------|

27.09.2017

Mario Gutbier

Stefan Jurgel

DK17-5102/7



SPEKTRA Schwingungstechnik und Akustik GmbH Dresden
Heidelberger Str. 12, DE-01189 Dresden - Tel. (0351) 4 00 24 731

9.59 Calibration certificate of noise level meter (page 2)

Seite 2 zum Kalibrierschein vom 27.09.2017
Page of calibration certificate dated

| |
|---------------------|
| 5 1 0 2 |
| D-K- 15183-01-00 |
| 2017-09 |

1. Kalibriergegenstand

| Gegenstand: | Hersteller: | Typ: | Serien-Nr: | Klassifizierung *) |
|------------------------------|-----------------|-----------------|---------------|--------------------|
| Schallpegelmesser | SVANTEK | SVAN 979 | 45290 | 1 |
| mit: | | | | |
| Mikrofonkapsel | G.R.A.S. | 40AE | 240597 | |
| Mikrofonvorverstärker | SVANTEK | SV 17 | 52127 | |

*) nach DIN EN 61672-1

Software **Svantek** **Version 1.26.2**

2. Kalibrierverfahren

Die akustische Kalibrierung erfolgte in Anlehnung an die Norm DIN EN 61672 im Freifeld nach dem Substitutionsverfahren im Schallfeld ebener, fortschreitender Wellen mit Sinustönen bekannten Schalldrucks, welche über eine Normalmesseinrichtung gemessen wurden. Die Richtung des Schalleinfalls war die Mikrofonlängsachse. Vor der Messung im Freifeld wurde der Schallpegelmesser am Bezugspegel 94 dB mit einem unmittelbar auf das nationale Normal rückgeführten akustischen Kalibrator auf den Referenzpegel justiert.

3. Umgebungsbedingungen

| | |
|------------------------------------|------------------------|
| Umgebungstemperatur des Prüflings: | (22,4 ± 1) °C |
| Relative Luftfeuchte: | (55 ± 5) % |
| Statischer Luftdruck: | (994,9 ± 1) hPa |

4. Messbedingungen

| | |
|---|----------------------------------|
| Einstellungen am Kalibriergegenstand: | |
| Zeitbewertung | Fast |
| Messbereiche | Tief (120 dB) |
| Frequenzbewertung | LIN, A, C |
| Mikrofon Kom.-Filter | Freifeld |
| Windschirm | aus |
| Mikrofonanschluss | abgesetzt über Kabelverlängerung |
| Einstellungen an der Normalmesseinrichtung: | |
| Frequenzbereich: | 125 Hz bis 20 kHz |
| Kalibrierpegel: | 84 dB |
| Abstand zur Schallquelle: | 84,0 cm |
| Filtertyp: | Sinusapproximation |
| Polarisationsspannung: | 200 V |
| Bezugsschalldruck: | 20 µPa |

DK17-5102/7



SPEKTRA Schwingungstechnik und Akustik GmbH Dresden
Heidelberaer Str 12 DE-01189 Dresden - Tel (0351) 4 00 24 731

9.60 Calibration certificate of noise level meter (page 3)

Seite 3 zum Kalibrierschein vom 27.09.2017
 Page of calibration certificate dated

| |
|---------------------|
| 5 1 0 2 |
| D-K- 15183-01-00 |
| 2017-09 |

5. Messunsicherheit

Die relativen Messunsicherheiten für die ausgewiesenen Werte betragen:

| | |
|--|----------------|
| - bei Ermittlung des Schalldruckpegels bei 1 kHz und 94 dB | 0,15 dB |
| - bei Ermittlung der Anzeigeabweichung im Freifeld | |
| 125 Hz bis <250 Hz | 0,35 dB |
| 250 Hz bis 8000 Hz | 0,30 dB |
| >8000 Hz bis 10000 Hz | 0,40 dB |
| >10000 Hz bis 20000 Hz | 0,45 dB |

Angegeben ist die erweiterte Messunsicherheit, die sich aus der Standardmessunsicherheit durch Multiplikation mit dem Erweiterungsfaktor $k = 2$ ergibt. Sie wurde gemäß DAkkS-DKD-3 ermittelt. Der Wert der Messgröße liegt mit einer Wahrscheinlichkeit von 95 % im zugeordneten Werteintervall.

6. Bestandteile der Normalmesseinrichtung

| | Hersteller | Typ | Serien-Nr. |
|---------------------------|------------------|-----------|------------|
| Schallpegelkalibrator | Brüel & Kjaer | 4231 | 2694377 |
| Messmikrofonkapsel | Brüel & Kjaer | 4191 FF | 2929550 |
| Mikrofonvorverstärker | Microtech Gefell | MV203 | 2329 |
| Kalibriersystem | SPEKTRA | CS18 AK 2 | 200717 |
| Reflexionsarme Messkammer | SPEKTRA | - | - |

7. Ergebnisse

7.1 Einpunktkalibrierung mit Kalibrator

Anzeige vor der Justage

| Messbereich in dB | Frequenz-, Zeit- bewertung | Frequenz in Hz | Schalldruck- pegel in dB | | Abweichung vom Sollwert in dB |
|----------------------|-------------------------------|-------------------|-----------------------------|---------|-------------------------------------|
| | | | Sollwert | Anzeige | |
| 120 | LIN, F | 1000 | 94,0 | 94,3 | 0,3 |

(Empfindlichkeit = 46,72 mV/Pa; C = 0,59 dB)

Anzeige nach der Justage

| Messbereich in dB | Frequenz-, Zeit- bewertung | Frequenz in Hz | Schalldruck- pegel in dB | | Abweichung vom Sollwert in dB |
|----------------------|-------------------------------|-------------------|-----------------------------|---------|-------------------------------------|
| | | | Sollwert | Anzeige | |
| 120 | LIN, F | 1000 | 94,0 | 94,1 | 0,1 |

(Empfindlichkeit = 47,53 mV/Pa; C = 0,44 dB)

DK17-5102/7*



SPEKTRA Schwingungstechnik und Akustik GmbH Dresden
 Heidelberger Str. 12 DE-01189 Dresden - Tel. (0351) 4 00 24 734

9.61 Calibration certificate of noise level meter (page 4)

Seite 4 zum Kalibrierschein vom 27.09.2017
 Page of calibration certificate dated

| |
|---------------------|
| 5 1 0 2 |
| D-K- 15183-01-00 |
| 2017-09 |

7.2 Anzeigeabweichung bei Pegel und Frequenz, Frequenzbewertung LIN

| Frequenz in Hz | Bereitgestellter Schalldruckpegel L_{LIN} in dB | Frequenzgang LIN-Bewertung in dB | Sollwert der Anzeige $L_{LIN,F}$ in dB | Anzeige am Schallpegelmessger $L_{LIN,F}$ in dB | Abweichung zur LIN - Bewertung in dB |
|-------------------|--|--|---|--|--|
| 125 | 84,0 | 0,0 | 84,0 | 84,1 | 0,1 |
| 160 | 84,0 | 0,0 | 84,0 | 84,1 | 0,1 |
| 200 | 84,0 | 0,0 | 84,0 | 84,1 | 0,1 |
| 250 | 84,0 | 0,0 | 84,0 | 84,1 | 0,1 |
| 315 | 84,0 | 0,0 | 84,0 | 84,0 | 0,0 |
| 400 | 84,0 | 0,0 | 84,0 | 84,1 | 0,1 |
| 500 | 84,0 | 0,0 | 84,0 | 84,1 | 0,1 |
| 630 | 84,0 | 0,0 | 84,0 | 84,2 | 0,2 |
| 800 | 84,1 | 0,0 | 84,1 | 84,3 | 0,2 |
| 1000 | 84,0 | 0,0 | 84,0 | 84,2 | 0,2 |
| 1250 | 84,0 | 0,0 | 84,0 | 84,1 | 0,1 |
| 1600 | 84,0 | 0,0 | 84,0 | 84,0 | 0,0 |
| 2000 | 84,0 | 0,0 | 84,0 | 84,3 | 0,3 |
| 2500 | 84,0 | 0,0 | 84,0 | 83,6 | -0,4 |
| 3150 | 84,0 | 0,0 | 84,0 | 84,0 | 0,0 |
| 4000 | 84,0 | 0,0 | 84,0 | 84,0 | 0,0 |
| 5000 | 84,0 | 0,0 | 84,0 | 84,1 | 0,1 |
| 6300 | 84,1 | 0,0 | 84,1 | 83,8 | -0,3 |
| 8000 | 84,1 | 0,0 | 84,1 | 84,2 | 0,1 |
| 10000 | 84,1 | 0,0 | 84,1 | 84,6 | 0,5 |
| 12500 | 84,1 | 0,0 | 84,1 | 84,8 | 0,7 |
| 16000 | 84,1 | 0,0 | 84,1 | 85,9 | 1,8 |
| 20000 | 84,1 | 0,0 | 84,1 | 85,4 | 1,3 |

DK17-51027



SPEKTRA Schwingungstechnik und Akustik GmbH Dresden
 Heidelberger Str. 12 DF-01189 Dresden - Tel (0351) 4 00 24 734

9.62 Calibration certificate of noise level meter (page 5)

Seite 5 zum Kalibrierschein vom 27.09.2017
Page of calibration certificate dated

| |
|---------------------|
| 5 1 0 2 |
| D-K- 15183-01-00 |
| 2017-09 |

7.3 Anzeigeabweichung bei Pegel und Frequenz, Frequenzbewertung A

| Frequenz in Hz | Bereitgestellter Schalldruckpegel L_{LIN} in dB | Frequenzgang A-Bewertung in dB | Sollwert der Anzeige $L_{A,F}$ in dB | Anzeige am Schallpegelmessger $L_{A,F}$ in dB | Abweichung zur A - Bewertung in dB |
|-------------------|--|--------------------------------------|---|--|--|
| 125 | 84,0 | -16,2 | 67,8 | 67,9 | 0,1 |
| 160 | 84,0 | -13,2 | 70,8 | 70,9 | 0,1 |
| 200 | 84,0 | -10,8 | 73,2 | 73,2 | 0,0 |
| 250 | 84,0 | -8,7 | 75,3 | 75,4 | 0,1 |
| 315 | 84,0 | -6,6 | 77,4 | 77,4 | 0,0 |
| 400 | 84,0 | -4,8 | 79,3 | 79,3 | 0,0 |
| 500 | 84,0 | -3,2 | 80,7 | 80,8 | 0,1 |
| 630 | 84,0 | -1,9 | 82,1 | 82,3 | 0,2 |
| 800 | 84,1 | -0,8 | 83,3 | 83,5 | 0,2 |
| 1000 | 84,0 | 0,0 | 84,0 | 84,2 | 0,2 |
| 1250 | 84,0 | 0,6 | 84,6 | 84,7 | 0,1 |
| 1600 | 84,0 | 1,0 | 85,0 | 85,0 | 0,0 |
| 2000 | 84,0 | 1,2 | 85,2 | 85,5 | 0,3 |
| 2500 | 84,0 | 1,3 | 85,3 | 84,9 | -0,4 |
| 3150 | 84,0 | 1,2 | 85,2 | 85,2 | 0,0 |
| 4000 | 84,0 | 1,0 | 85,0 | 85,0 | 0,0 |
| 5000 | 84,0 | 0,6 | 84,6 | 84,8 | 0,2 |
| 6300 | 84,1 | -0,1 | 84,0 | 83,8 | -0,2 |
| 8000 | 84,1 | -1,1 | 82,9 | 83,2 | 0,3 |
| 10000 | 84,1 | -2,5 | 81,6 | 82,2 | 0,6 |
| 12500 | 84,1 | -4,3 | 79,8 | 80,5 | 0,7 |
| 16000 | 84,1 | -6,7 | 77,4 | 79,0 | 1,6 |
| 20000 | 84,1 | -9,3 | 74,7 | 76,1 | 1,4 |

DK17-5102/7



SPEKTRA Schwingungstechnik und Akustik GmbH Dresden
Heidelberger Str. 12, DE-01189 Dresden - Tel. (0351) 4 00 24 731

9.63 Calibration certificate of noise level meter (page 6)

Seite 6 zum Kalibrierschein vom 27.09.2017
 Page of calibration certificate dated

| |
|---------------------|
| 5 1 0 2 |
| D-K- 15183-01-00 |
| 2017-09 |

7.4 Anzeigeabweichung bei Pegel und Frequenz, Frequenzbewertung C

| Frequenz in Hz | Bereitgestellter Schalldruckpegel L_{LIN} in dB | Frequenzgang C-Bewertung in dB | Sollwert der Anzeige $L_{C,F}$ in dB | Anzeige am Schallpegelmesser $L_{C,F}$ in dB | Abweichung zur C - Bewertung in dB |
|-------------------|--|--------------------------------------|---|---|--|
| 125 | 84,0 | -0,2 | 83,8 | 83,9 | 0,1 |
| 160 | 84,0 | -0,1 | 83,9 | 84,1 | 0,2 |
| 200 | 84,0 | 0,0 | 84,0 | 84,1 | 0,1 |
| 250 | 84,0 | 0,0 | 84,0 | 84,1 | 0,1 |
| 315 | 84,0 | 0,0 | 84,0 | 84,1 | 0,1 |
| 400 | 84,0 | 0,0 | 84,1 | 84,1 | 0,0 |
| 500 | 84,0 | 0,0 | 84,0 | 84,0 | 0,0 |
| 630 | 84,0 | 0,0 | 84,1 | 84,3 | 0,2 |
| 800 | 84,1 | 0,0 | 84,1 | 84,3 | 0,2 |
| 1000 | 84,0 | 0,0 | 84,0 | 84,2 | 0,2 |
| 1250 | 84,0 | 0,0 | 84,0 | 84,1 | 0,1 |
| 1600 | 84,0 | -0,1 | 83,9 | 83,9 | 0,0 |
| 2000 | 84,0 | -0,2 | 83,9 | 84,1 | 0,2 |
| 2500 | 84,0 | -0,3 | 83,7 | 83,3 | -0,4 |
| 3150 | 84,0 | -0,5 | 83,5 | 83,5 | 0,0 |
| 4000 | 84,0 | -0,8 | 83,2 | 83,2 | 0,0 |
| 5000 | 84,0 | -1,3 | 82,8 | 82,9 | 0,1 |
| 6300 | 84,1 | -2,0 | 82,1 | 81,9 | -0,2 |
| 8000 | 84,1 | -3,0 | 81,0 | 81,3 | 0,3 |
| 10000 | 84,1 | -4,4 | 79,7 | 80,3 | 0,6 |
| 12500 | 84,1 | -6,2 | 77,9 | 78,6 | 0,7 |
| 16000 | 84,1 | -8,6 | 75,5 | 77,1 | 1,6 |
| 20000 | 84,1 | -11,3 | 72,8 | 74,2 | 1,4 |

DK17-5102/7




SPEKTRA Schwingungstechnik und Akustik GmbH Dresden
 Heidelberger Str. 12. DE-01189 Dresden - Tel. (0351) 4 00 24 731

9.64 Calibration certificate of noise level meter (page 7)

Seite 7 zum Kalibrierschein vom 27.09.2017
 Page 7 of calibration certificate dated

| |
|---------------------|
| 5 1 0 2 |
| D-K- 15183-01-00 |
| 2017-09 |

7.5 Anzeigeabweichung im Frequenzbereich 125 Hz bis 20 kHz



7.6 Konformität

Die ermittelten Kennwerte liegen innerhalb der für Klasse 1 nach 61672-1 festgelegten Grenzwerte. Die **Konformität mit DIN EN 61672-1 ist für die im Kalibrierschein ermittelten Kennwerte gegeben.**

DK17-5102/7



SPEKTRA Schwingungstechnik und Akustik GmbH Dresden
 Heidelberger Str. 12, DE-01189 Dresden - Tel. (0351) 4 00 24 731

9.65 Calibration certificate of anemometer (page 1)



Deutsche WindGuard
Wind Tunnel Services GmbH



accredited by the / akkreditiert durch die

Deutsche Akkreditierungsstelle GmbH

as calibration laboratory in the / als Kalibrierlaboratorium im

Deutschen Kalibrierdienst



Deutsche
Akkreditierungsstelle
D-K-15140-01-00

Calibration certificate
Kalibrierschein

Calibration mark
Kalibrierzeichen

| |
|-------------|
| 1823138 |
| D-K- |
| 15140-01-00 |
| 09/2018 |

| | |
|---|---|
| Object <i>Gegenstand</i> | 2D Sonic Anemometer |
| Manufacturer <i>Hersteller</i> | Thies Clima D-37083 Göttingen |
| Type <i>Typ</i> | 4.9201.00.000 |
| Serial number <i>Fabrikat/Serien-Nr.</i> | 06160031 |
| Customer <i>Auftraggeber</i> | GL Garrad Hassan D-25709 Kaiser-Wilhelm-Koog |
| Order No. <i>Auftragsnummer</i> | PO19194/CC102372/Mdf/AZm |
| Project No. <i>Projektnummer</i> | VT180883 |
| Number of pages <i>Anzahl der Seiten</i> | 5 |
| Date of Calibration <i>Datum der Kalibrierung</i> | 26.09.2018 |

This calibration certificate documents the traceability to national standards, which realize the units of measurement according to the International System of Units (SI).
The DAkkS is signatory to the multilateral agreements of the European co-operation for Accreditation (EA) and of the International Laboratory Accreditation Cooperation (ILAC) for the mutual recognition of calibration certificates. The user is obliged to have the object recalibrated at appropriate intervals.
Dieser Kalibrierschein dokumentiert die Rückführung auf nationale Normale zur Darstellung der Einheiten in Übereinstimmung mit dem Internationalen Einheitensystem (SI). Die DAkkS ist Unterzeichner der multilateralen Übereinkommen der European co-operation for Accreditation (EA) und der International Laboratory Accreditation Cooperation (ILAC) zur gegenseitigen Anerkennung der Kalibrierscheine. Für die Einhaltung einer angemessenen Frist zur Wiederholung der Kalibrierung ist der Benutzer verantwortlich.

This calibration certificate may not be reproduced other than in full except with the permission of both the German Accreditation Body and the issuing laboratory. Calibration certificates without signature are not valid. This calibration certificate has been generated electronically.
Dieser Kalibrierschein darf nur vollständig und unverändert weiterverbreitet werden. Auszüge oder Änderungen bedürfen der Genehmigung sowohl der Deutschen Akkreditierungsstelle als auch des ausstellenden Kalibrierlaboratoriums. Kalibrierscheine ohne Unterschrift haben keine Gültigkeit. Dieser Kalibrierschein wurde elektronisch erzeugt.

| | | |
|----------------------|--|---------------------------------------|
| Date <i>Datum</i> | Head of the calibration laboratory <i>Leiter des Kalibrierlaboratoriums</i> | Person in charge <i>Bearbeiter</i> |
| 26.09.2018 | Dipl. Phys. Dieter Westermann | Kai Schuster, B. Eng. |

9.66 Calibration certificate of anemometer (page 2)

Page 2 / 5
Seite

| |
|-------------|
| 1823138 |
| D-K- |
| 15140-01-00 |
| 09/2018 |

| | | | | | | | | | | | |
|---|---|------------------|-----------------------|-------------------------|----------------------|---------------------------|------------------|------------------------------|-----------|------------------|----------|
| Calibration object <i>Kalibriergegenstand</i> | 2D Sonic Anemometer | | | | | | | | | | |
| Calibration procedure <i>Kalibrierverfahren</i> | IEC 61400-12-1:2017 | | | | | | | | | | |
| Place of calibration <i>Ort der Kalibrierung</i> | Wind tunnel of Deutsche WindGuard WindTunnel Services GmbH, Varel | | | | | | | | | | |
| Test conditions <i>Messbedingungen</i> | <table border="0"> <tr> <td>wind tunnel area</td> <td>10000 cm²</td> </tr> <tr> <td>anemometer frontal area</td> <td>340 cm²</td> </tr> <tr> <td>diameter of mounting pipe</td> <td>48.0 mm EN 10217</td> </tr> <tr> <td>blockage ratio ¹⁾</td> <td>0.034 [-]</td> </tr> <tr> <td>software version</td> <td>P_7.8.05</td> </tr> </table> <p>¹⁾ Due to the special construction of the test section no blockage correction is necessary.</p> | wind tunnel area | 10000 cm ² | anemometer frontal area | 340 cm ² | diameter of mounting pipe | 48.0 mm EN 10217 | blockage ratio ¹⁾ | 0.034 [-] | software version | P_7.8.05 |
| wind tunnel area | 10000 cm ² | | | | | | | | | | |
| anemometer frontal area | 340 cm ² | | | | | | | | | | |
| diameter of mounting pipe | 48.0 mm EN 10217 | | | | | | | | | | |
| blockage ratio ¹⁾ | 0.034 [-] | | | | | | | | | | |
| software version | P_7.8.05 | | | | | | | | | | |
| Ambient conditions <i>Umgebungsbedingungen</i> | <table border="0"> <tr> <td>air temperature</td> <td>23.1 °C ± 0.1 °C</td> </tr> <tr> <td>air pressure</td> <td>1028.8 hPa ± 0.3 hPa</td> </tr> <tr> <td>relative air humidity</td> <td>42.9 % ± 2.0 %</td> </tr> </table> | air temperature | 23.1 °C ± 0.1 °C | air pressure | 1028.8 hPa ± 0.3 hPa | relative air humidity | 42.9 % ± 2.0 % | | | | |
| air temperature | 23.1 °C ± 0.1 °C | | | | | | | | | | |
| air pressure | 1028.8 hPa ± 0.3 hPa | | | | | | | | | | |
| relative air humidity | 42.9 % ± 2.0 % | | | | | | | | | | |
| Measurement uncertainty <i>Messunsicherheit</i> | <p>The expanded uncertainty assigned to the measurement results is obtained by multiplying the standard uncertainty by the coverage factor $k=2$. It has been determined in accordance with DAkkS-DKD-3. The value of the measurand lies within the assigned range of values with a probability of 95%.</p> <p>The reference flow speed measurement is traceable to the German NMI (Physikalisch-Technische Bundesanstalt) standard for flow speed. It is realized by using a PTB owned and calibrated Laser Doppler Anemometer (Standard Uncertainty 0.2 %, $k=2$)</p> | | | | | | | | | | |
| Additional remarks <i>Zusätzliche Anmerkungen</i> | Orientation: 0° | | | | | | | | | | |

Deutsche WindGuard
Wind Tunnel Services GmbH, Varel



9.67 Calibration certificate of anemometer (page 3)

Page 3 / 5
Seite

| |
|-------------|
| 1823138 |
| D-K- |
| 15140-01-00 |
| 09/2018 |

Calibration result Kalibrierergebnis

| Reference | Reference | Test item | Test item |
|--------------|-----------|-----------|-----------|
| Air velocity | Unc | Speed | Direction |
| m/s | m/s | m/s | deg |
| 3.943 | 0.05 | 3.959 | 359.794 |
| 6.001 | 0.05 | 6.014 | 360.000 |
| 7.958 | 0.05 | 7.960 | 360.000 |
| 9.879 | 0.05 | 9.903 | 360.000 |
| 11.949 | 0.05 | 12.001 | 360.000 |
| 13.916 | 0.05 | 13.956 | 360.000 |
| 15.937 | 0.05 | 15.982 | 360.000 |
| 14.912 | 0.05 | 14.954 | 360.000 |
| 12.912 | 0.05 | 12.954 | 360.000 |
| 10.904 | 0.05 | 10.941 | 360.000 |
| 8.914 | 0.05 | 8.936 | 360.000 |
| 7.016 | 0.05 | 7.017 | 360.000 |
| 5.026 | 0.05 | 5.019 | 359.975 |

| | | |
|-----------------------------|-------------------------|--|
| Statistical analysis | Slope | 0.99580 (m/s)/(m/s) ±0.00079 (m/s)/(m/s) |
| | Offset | 0.0168 m/s ±0.008 m/s |
| | Standard error (Y) | 0.011 m/s |
| | Correlation coefficient | 0.999997 |

Remarks The calibrated sensor complies with the demanded linearity of MEASNET



Deutsche WindGuard
Wind Tunnel Services GmbH, Varel



9.68 Calibration certificate of anemometer (page 4)

Page 4 / 5
Seite

| |
|-------------|
| 1823138 |
| D-K- |
| 15140-01-00 |
| 09/2018 |

Graphical representation of the result
Grafische Darstellung des Ergebnisses





Photo of the measurement setup
Foto des Messaufbaus



Remark: The proportions of the set-up may not be true to scale due to imaging geometry.

Deutsche WindGuard
Wind Tunnel Services GmbH, Varel



9.69 Calibration certificate of anemometer (page 5)

Page 5 / 5
Seite

| |
|-------------|
| 1823138 |
| D-K- |
| 15140-01-00 |
| 09/2018 |

Sensor config during calibration
Sensorkonfiguration während der Kalibrierung

| | |
|-----------|---------------|
| 00AB80106 | 00OS00000 |
| 00AH00100 | 00PE00016 |
| 00AL00120 | 00PH00260 |
| 00AM00001 | 00PN00002 |
| 00AO00001 | 00PT00010 |
| 00AP00100 | 00PW00060 |
| 00AQ00100 | 00RD00005 |
| 00AR00060 | 00RT00000 |
| 00AT14060 | 00SH00000 |
| 00AV00010 | 00SM00000 |
| 00BO00000 | 00SN06160031 |
| 00BP00008 | 00ST00001 |
| 00BR00096 | 00SV00401 |
| 00BT00000 | 00TA920100000 |
| 00CI00000 | 00TT00002 |
| 00DM00001 | 00TZ00000 |
| 00DO00001 | |
| 00DT00000 | |
| 00EI00000 | |
| 00ET00030 | |
| 00HC00010 | |
| 00HH00000 | |
| 00HP00010 | |
| 00HS00001 | |
| 00HT00000 | |
| 00ID00000 | |
| 00II00000 | |
| 00KY00000 | |
| 00MC00000 | |
| 00NC00000 | |
| 00OL12789 | |
| 00OP00000 | |
| 00OR01000 | |

Deutsche WindGuard
Wind Tunnel Services GmbH, Varel

DEUTSCHE
WINDGUARD

9.70 Extract of the calibration certificate of secondary wind screen

DNV·GL

Extract of the test report GLGH 4286 11 07555 000-C-0075-A




Figure 1: Insertion loss of the secondary windscreen EWS-15-10 without optional weatherproof cover (mean and standard deviation of 12 individual measurements)





Figure 2: insertion loss of the secondary windscreen EWS-15-10 with optional weatherproof cover (mean and standard deviation of 12 individual measurements)

9.71 Position of the test site

Source: www.openstreetmap.org



9.72 Photos



Photo 1: Measured turbine of the type Vestas V150-4.2 MW 50 Hz



Photo 2: Photo from the wind met mast toward the turbine



Photo 3: Photo from microphone and board



ABOUT DNV GL

Driven by our purpose of safeguarding life, property and the environment, DNV GL enables organizations to advance the safety and sustainability of their business. We provide classification and technical assurance along with software and independent expert advisory services to the maritime, oil and gas, and energy industries. We also provide certification services to customers across a wide range of industries. Operating in more than 100 countries, our professionals are dedicated to helping our customers make the world safer, smarter and greener